



RAINWATER TANK SIZE SELECTION TABLE

Percentage of time rainwater tank will meet full domestic daily demand at MOUNT BARKER (Average Annual Rainfall – 834 mm)

HOW TO USE THIS TABLE

- STEP 1** Identify proposed **roof area**.
- STEP 2** Identify **Rainwater Use Option**.
- STEP 3** Identify **tank capacity**.
- STEP 4** Identify the category (colour code) the roof area, rainwater use option and tank capacity combination fall within.
- STEP 5** Refer to **Legend**.
- STEP 6** (if required) Select larger roof area (if possible), alternative rainwater use option and/or larger tank capacity and repeat STEPS 1 to 5.

NOTES

- 1 For all options within the orange (16 - 50%) and yellow (51 - 75%) range, it is recommended that the following variations to your proposal be considered to maximise the value of your rainwater tank selection:-
 - increase the roof area to be connected to the rainwater tank, if possible;
 - select a larger tank; and/or
 - change to water use efficient devices within the home, eg front loading washing machine (can save up to 20% of average daily water demand per household).
- 2 This “Rainwater Tank Size Selection Table” should be read in conjunction with the Board’s “Rainwater Tank Use Information Sheet”.
- 3 This “Rainwater Tank Size Selection Table” DOES NOT ALLOW FOR WATER STORAGE FOR FIRE FIGHTING REQUIREMENTS.
- 4 The internal water use estimates are based upon a 3 person household.
- 5 For advice beyond the scope of this table (eg tanks smaller than 9,000L or larger than 22,000L) please contact the SA Murray-Darling Basin NRM Board on Ph: 8532 1432.

Rainwater Use Option		High internal use			Medium internal use 1			Medium internal use 2			Low grade uses			
Description		11L single flush toilet, 100% laundry (front load WM) & HWS			(6/3L) Dual flush toilet, AAA-rated shower head, 100% laundry (top load WM) & HWS			(6/3L) Dual flush toilet, AAA-rated shower head, 100% laundry (front load WM) & HWS			(6/3L) Dual flush toilet and 100% laundry (front load WM) <u>only</u>			
Tank capacity (L)		9,000	13,500	22,000	9,000	13,500	22,000	9,000	13,500	22,000	1,000	9,000	13,500	22,000
Roof area to be connected to rainwater tank (m ²)	50	11%	11%	11%	21%	21%	21%	31%	31%	31%	57%	79%	79%	79%
	100	34%	34%	34%	56%	57%	58%	72%	76%	77%	75%	97%	99%	99%
	150	56%	58%	59%	76%	81%	87%	85%	90%	97%	82%	99%	99%	99%
	200	69%	73%	79%	82%	87%	94%	90%	94%	98%	86%	99%	99%	99%

LEGEND

Category	Effectiveness of chosen roof area and tank capacity to meet full domestic daily demand	Recommendation
	Rainwater tank will meet full daily demand 0 – 15 % of the time.	Not recommended
	Rainwater tank will meet full daily demand 16 – 50% of the time.	Satisfactory, but alternative recommended for the intended use (refer to Note 1).
	Rainwater tank will meet full daily demand 51 – 75% of the time.	Satisfactory, but alternative recommended for the intended use (refer to Note 1).
	Rainwater tank will meet full daily demand 76 – 90% of the time.	Recommended – Roof area and tank capacity selected are suitable for the intended use.
	Rainwater tank will meet full daily demand 91 - 100% of the time.	Highly recommended – Roof area and tank capacity selected are suitable for the intended use.

Acronyms

HWS Hot water service
 WM Washing machine
 WC Toilet